

ACTION PLAN FOR THE REMEDIATION OF LEAD IN WATER

LOCKPORT TOWNSHIP HIGH SCHOOL DISTRICT 205

SITES TESTED

EAST CAMPUS - CENTRAL CAMPUS - OTHER DISTRICT FACILITIES & GROUNDS

The Action Plan's goal is to provide safe drinking water to our students, staff and visitors. We learned a great deal about our water since we started testing the water for lead. Our remediation plan uses various methods to reduce/eliminate lead from our drinking water. The various methods that we used are:

1. Replaced old drinking fountains with new filtered bottle fillers
2. Replaced old faucets with new American made faucets that state lead free on faucet
3. Installed lead free filters on water fountains and faucets.
4. Installed water flush valves that purge the line of water for one minute twice a day. Once before school starts and once before practice starts.
5. Installed signs above the sink in offices that state: Not For Consumption (This sign was installed on any faucet that had a first or second draw above 5ppb)
6. Installed signs above other sinks in offices that state: Run Water For 30 Seconds Before Consumption. (This sign was installed on water sources whose first draw was under 5ppm and second draw was under 2ppb)
7. Installed signs near outdoor water sources that state: Run Water For 30 Seconds Before Consumption (This was done only on water sources whose first draw was under 5ppb and second draw was under 2ppb). Each of these water sources has a lead free filter but still had a first draw reading above 2ppb but below 5ppb and a second draw reading below 2ppb.

We continue to be diligent in providing safe drinking water to all our students, staff and visitors. The water source that comes from wells from the City of Lockport has a threshold of 15ppb, much higher than what is required of schools. It has been a challenge to meet the State requirements but over time and many retests, we have achieved our goal and are confident that all our water sources meet or exceed the State requirements.

LIST OF WATER FOUNTAINS AND SINKS FOR DRINKING/COOKING IN 2018

#	LOCATION	TYPE	INSTALLED	DRAW	RESULT
1	Room 200	T&S Faucet	1996	FD	6.47
1	Room 200	T&S Faucet	1996	SD	ND
Installed Sign: Not for Consumption					
2	Room 211	T&S Faucet	1996	FD	4.83
2	Room 211	T&S Faucet	1996	SD	ND
Installed Sign: Run Water for 30 Seconds Before Consumption					
3	O Hallway	Elkay W.F.	1996	FD	1.02
3	O Hallway	Elkay W.F.	1996	SD	ND
4	O Hallway	Elkay W.F.	1996	FD	ND
4	O Hallway	Elkay W.F.	1996	SD	ND
5	O Hallway	Elkay Bottle Filler (S)	2014	FD	ND
5	O Hallway	Elkay Bottle Filler (B)	2014	FD	ND
5	O Hallway	Elkay Bottle Filler (S)	2014	SD	ND
6	N Hallway	Elkay Bottle Filler (S)	2017	FD	ND
6	N Hallway	Elkay Bottle Filler(B)	2017	FD	ND
6	N Hallway	Elkay Bottle Filler(S)	2017	SD	ND
7	N Hallway	Elkay W.F.	1996	FD	1.07
7	N Hallway	Elkay W.F.	1996	SD	ND
8	N Hallway	Elkay W.F.	1996	FD	ND
8	N Hallway	Elkay W.F.	1996	SD	ND
9	Room 3	T&S Faucet	1996	FD	21.9
9	Room 3	T&S Faucet	1996	SD	2.92
Installed Sign: Not for Consumption					
10	Hallway A	Elkay W.F.	1996	FD	ND
10	Hallway A	Elkay W.F.	1996	SD	ND
11	Hallway A	Elkay W.F.	1996	FD	ND
11	Hallway A	Elkay W.F.	1996	SD	ND
12	Hallway A	Elkay W.F.	1996	FD	ND
12	Hallway A	Elkay W.F.	1996	SD	ND

#	LOCATION	TYPE	INSTALLED	DRAW	RESULT
13	Room 10	T&S Faucet	1996	FD	3.32
13	Room 10	T&S Faucet	1996	SD	1.12
Installed Sign: Run Water for 30 Seconds Before Consumption					
14	Room 22	T&S Faucet	1996	FD	7.70
14	Room 22	T&S Faucet	1996	SD	ND
Installed Sign: Not for Consumption					
15	Room 23	T&S Faucet	1996	FD	3.76
15	Room 23	T&S Faucet	1996	SD	ND
Installed Sign: Run Water for 30 Seconds Before Consumption					
16	Hallway B	Elkay W.F.	1996	FD	1.34
16	Hallway B	Elkay W.F.	1996	SD	1.71
17	Hallway B	Elkay W.F.	1996	FD	ND
17	Hallway B	Elkay W.F.	1996	SD	ND
18	Hallway B	Elkay W.F.	1996	FD	1.57
18	Hallway B	Elkay W.F.	1996	SD	ND
19	Hallway C	Elkay W.F.	1996	FD	ND
19	Hallway C	Elkay W.F.	1996	SD	ND
20	Hallway C	Elkay W.F.	1996	FD	ND
20	Hallway C	Elkay W.F.	1996	SD	ND
21	Room 43	T&S Faucet	1996	FD	2.72
21	Room 43	T&S Faucet	1996	SD	ND
Installed Sign: Run Water for 30 Seconds Before Consumption					
22	Room 53	Moen Faucet	2009	FD	7.03
22	Room 53	Moen Faucet	2009	SD	1.23
Installed Sign: Not for Consumption					
23	E&K Hallway	Halsey Taylor W.F.	2010	FD	1.16
23	E&K Hallway	Halsey Taylor W.F.	2010	SD	ND
24	F&K Hallway	Halsey Taylor W.F.	2010	FD	1.82
24	F&K Hallway	Halsey Taylor W.F.	2010	SD	1.65
25	K Hallway Media	SK Culver W.F.	2010	FD	ND
25	K Hallway Media	SK Culver W.F.	2010	SD	ND
26	Media Center	Chicago Faucet	1996	FD	14.4
26	Media Center	Chicago Faucet	1996	SD	1.41
Installed Sign: Not for Consumption					
27	Hallway Faucet	Moen Faucet	2010	FD	Removed
27	Hallway Faucet	Moen Faucet	2010	SD	from Service

#	LOCATION	TYPE	INSTALLED	DRAW	RESULT
28	Child Lab Sink		2017	FD	1.69
28	Child Lab Sink		2017	SD	ND
29	Room 95 (1)		2017	FD	1.45
29	Room 95 (1)		2017	SD	ND
30	Room 95 (2)		2017	FD	1.29
30	Room 95 (2)		2017	SD	ND
31	Room 95 (3)		2017	FD	1.30
31	Room 95 (3)		2017	SD	ND
32	Room 95 (4)		2017	FD	1.47
32	Room 95 (4)		2017	SD	1.08
33	Room 95 (5)		2017	FD	1.44
33	Room 95 (5)		2017	SD	ND
34	Room 95 (6)		2017	FD	1.18
34	Room 95 (6)		2017	SD	ND
35	Room 95 (7)		2017	FD	ND
35	Room 95 (7)		2017	SD	ND
36	Hallway G&K	Elkay Bottle Filler (S)	2016	FD	ND
36	Hallway G&K	Elkay Bottle Filler (B)	2016	FD	ND
36	Hallway G&K	Elkay Bottle Filler (S)	2016	SD	ND
37	Hallway K-Gym	Elkay Bottle Filler	2014	FD	ND
37	Hallway K-Gym	Elkay Bottle Filler	2014	FD	ND
37	Hallway K-Gym	Elkay Bottle Filler (S)	2014	SD	ND
38	Main. Shop Sink	Tuscany Brass Faucet	2010	FD	1.44
38	Main. Shop Sink	Tuscany Brass Faucet	2010	SD	ND
39	Hallway G	Halsey Taylor W.F.	2005	FD	ND
39	Hallway G	Halsey Taylor W.F.	2005	SD	ND
40	Principal Office	T&S Faucet	1996	FD	5.14
40	Principal Office	T&S Faucet	1996	SD	ND
Installed Sign: Not for Consumption					
41	PPS Office	T&S Faucet	1996	FD	3.91
41	PPS Office	T&S Faucet	1996	SD	ND
Installed Sign: Run Water for 30 Seconds Before Consumption					
42	Nurses Office (1)	T&S Faucet	1996	FD	18.1
42	Nurses Office (1)	T&S Faucet	1996	SD	2.54
Install Sign Not for Consumption					
43	Nurses Office (2)	T&T Faucet	1996	FD	10.2
43	Nurses Office (2)	T&T Faucet	1996	SD	ND
Removed From Service Nurse uses bottled water when needed					

#	LOCATION	TYPE	INSTALLED	DRAW	RESULT
44	Tech. Break Room	Franke Faucet	2000	FD	3.93
44	Tech. Break Room	Franke Faucet	2000	SD	1.52
Installed Sign: Run Water for 30 Seconds Before Consumption					
45	Hallway J	Halsey Taylor W.F.	1996	FD	ND
45	Hallway J	Halsey Taylor W.F.	1996	SD	ND
46	Cafeteria (1)	Elkay W.F.	1996	FD	ND
46	Cafeteria (1)	Elkay W.F.	1996	SD	ND
47	Cafeteria (2)	Elkay W.F.	1996	FD	ND
47	Cafeteria (2)	Elkay W.F.	1996	SD	ND
48	Cafeteria (3)	Elkay W.F.	1996	FD	ND
48	Cafeteria (3)	Elkay W.F.	1996	SD	ND
49	Cafeteria (4)	Elkay W.F.	1996	FD	ND
49	Cafeteria (4)	Elkay W.F.	1996	SD	ND
50	Café Deli Bar (5)	Faucet	2016	FD	Not for
50	Café Deli Bar (5)	Faucet	2016	SD	Consumption
51	Kitchen (1)	Chicago Faucet	1996	FD	Not for
51	Kitchen (1)	Chicago Faucet	1996	SD	Consumption
52	Kitchen (2)	Chicago Faucet	1996	FD	Not for
52	Kitchen (2)	Chicago Faucet	1996	SD	Consumption
53	Kitchen (3)	Chicago Faucet	1996	FD	Not for
53	Kitchen (3)	Chicago Faucet	1996	SD	Consumption
54	Kitchen (4)	Chicago Faucet	1996	FD	3.38
54	Kitchen (4)	Chicago Faucet	1996	SD	1.53
Installed Sign: Run Water for 30 Seconds Before Consumption					
55	Kitchen (5)	Chicago Faucet	2009	FD	ND
55	Kitchen (5)	Chicago Faucet	2009	SD	ND
56	Field House South	Elkay W.F.	1996	FD	1.31
56	Field House South	Elkay W.F.	1996	SD	ND
57	Field House South	Elkay W.F.	1996	FD	1.23
57	Field House South	Elkay W.F.	1996	SD	ND
58	CWC (1)	Elkay W.F.	1996	FD	1.46
58	CWC (1)	Elkay W.F.	1996	SD	1.47
59	CWC (2)	Elkay W.F.	1996	FD	1.11
59	CWC (2)	Elkay W.F.	1996	SD	ND

#	LOCATION	TYPE	INSTALLED	DRAW	RESULT
60	CWC (3)	Elkay W.F.	1996	FD	ND
60	CWC (3)	Elkay W.F.	1996	SD	ND
61	CWC (4)	Elkay W.F.	1996	FD	ND
61	CWC (4)	Elkay W.F.	1996	SD	ND
62	CWC (5)	Elkay Bottle Filler (S)	2014	FD	1.57
62	CWC (5)	Elkay Bottle Filler (B)	2014	FD	ND
62	CWC (5)	Elday Bottle Filler (S)	2014	SD	ND
63	CWC Pump Room	T&S Faucet	1996	FD	3.46
63	CWC Pump Room	T&S Faucet	1996	SD	1.02
Installed Sign: Run Water for 30 Seconds Before Consumption					
64	Boys Swim L.R.	Elkay W.F.	1996	FD	ND
64	Boys Swim L.R.	Elkay W.F.	1996	SD	ND
65	Girls Swim L.R.	Elkay W.F.	1996	FD	ND
65	Girls Swim L.R.	Elkay W.F.	1996	SD	ND
66	CWC Concession	T&S Faucet	1996	FD	2.26
66	CWC Concession	T&S Faucet	1996	SD	1.02
Installed Sign: Run Water for 30 Seconds Before Consumption					
67	Field House (1)	Elkay W.F.	1996	FD	ND
67	Field House (1)	Elkay W.F.	1996	SD	ND
68	Field House (S)	Elkay W.F.	1996	FD	1.04
68	Field House (S)	Elkay W.F.	1996	SD	1.01
69	Field House (3)	Elkay Bottle Filler (S)	2012	FD	ND
69	Field House (3)	Elkay Bottle Filler (B)	2012	FD	ND
69	Field House (3)	Elkay Bottle Filler (S)	2012	SD	ND
70	Boys PE Locker Room (1)	Elkay W.F.	1996	FD	1.36
70	Boys PE Locker Room (1)	Elkay W.F.	1996	SD	1.09
71	Boys PE Locker Room (2)	Elkay W.F.	1996	FD	ND
71	Boys PE Locker Room (2)	Elkay W.F.	1996	SD	ND
72	Girls PE Locker Room (1)	Elkay W.F.	1996	FD	1.12
72	Girls PE Locker Room (1)	Elkay W.F.	1996	SD	1.01
73	Girls PE Locker Room (2)	Elkay W.F.	1996	FD	1.42
73	Girls PE Locker Room (2)	Elkay W.F.	1996	SD	1.31
74	Weight Room 106	Elkay W.F.	1996	FD	ND
74	Weight Room 106	Elkay W.F.	1996	SD	1.79
75	Weight Room 112	Elkay W.F.	1996	FD	1.24
75	Weight Room 112	Elkay W.F.	1996	SD	1.26

76	Weight Room 117 (1)	Elkay W.F.	1996	FD	ND
76	Weight Room 117 (1)	Elkay W.F.	1996	SD	ND
77	Weight Room 117 (2)	Elkay W.F.	1996	FD	ND
77	Weight Room 117 (2)	Elkay W.F.	1996	SD	ND
78	Dance Studio	Elkay W.F.	1996	FD	ND
78	Dance Studio	Elkay W.F.	1996	SD	ND
79	Room 1	Elkay W.F.	1996	FD	1.62
79	Room 1	Elkay W.F.	1996	SD	1.20
80	Auditorium Lobby East 1	Elkay W. F.	1996	FD	ND
80	Auditorium Lobby East 1	Elkay W. F.	1996	SD	ND
81	Auditorium Lobby East 2	Elkay W.F.	1996	FD	ND
81	Auditorium Lobby East 2	Elkay W.F.	1996	SD	ND
82	Auditorium Lobby East 3	Elkay W.F.	1996	FD	ND
82	Auditorium Lobby East 3	Elkay W.F.	1996	SD	ND
83	Auditorium Lobby West 1	Elkay W.F.	1996	FD	ND
83	Auditorium Lobby West 1	Elkay W.F.	1996	SD	ND
84	Auditorium Lobby West 2	Elkay W.F.	1996	FD	ND
84	Auditorium Lobby West 2	Elkay W.F.	1996	SD	ND
85	Auditorium Lobby West 3	Elkay W.F.	1996	FD	3.05
85	Auditorium Lobby West 3	Elkay W.F.	1996	SD	4.03
<i>Took Out of Service Will Replace with Filtered Water Fountain Retest once new W.F. Installed</i>					
86	Serving Line in Café	Chicago Faucet	1996	FD	Not for
86	Serving Line in Café	Chicago Faucet	1996	SD	Consumption
87	Serving Line in Café	Chicago Faucet	1996	FD	Not for
87	Serving Line in Café	Chicago Faucet	1996	SD	Consumption
88	Faculty Café Sink	Chicago Faucet	2016	FD	Not for
88	Faculty Café Sink	Chicago Faucet	2016	SD	Consumption
89	Pump Room Water Inlet	Past Water Meter	1996	FD	134
89	Pump Room Water Inlet	Past Water Meter	1996	SD	5.47
<i>Installed Sign: Not for Consumption</i>					
90	Pool Deck	Elkay Bottle Filler	2018	FD	ND
90	Pool Deck	Elkay Bottle Filler	2018	FD	ND
90	Pool Deck	Elkay Bottle Filler	2018	SD	ND
91	Pool Deck 2	Elkay W.F.	1996	FD	2.09
91	Pool Deck 2	Elkay W.F.	1996	SD	2.95

Removed from Service

#	LOCATION	TYPE	INSTALLED	DRAW	RESULT
92	<i>Trainers Room Sink South</i>	<i>Chicago Faucet</i>	<i>1996</i>	<i>FD</i>	<i>4.49</i>
92	<i>Trainers Room Sink South</i>	<i>Chicago Faucet</i>	<i>1996</i>	<i>SD</i>	<i>ND</i>
Installed Sign: Run Water for 30 Seconds Before Consumption					
93	<i>Trainers Room Sink North</i>	<i>Chicago Faucet</i>	<i>1996</i>	<i>FD</i>	<i>2.30</i>
93	<i>Trainers Room Sink North</i>	<i>Chicago Faucet</i>	<i>1996</i>	<i>SD</i>	<i>ND</i>
Installed Sign: Run Water for 30 Seconds Before Consumption					
94	<i>Balcony Wrestling W.F.</i>	<i>Elkay W.F.</i>	<i>1996</i>	<i>FD</i>	<i>ND</i>
94	<i>Balcony Wrestling W.F.</i>	<i>Elkay W.F.</i>	<i>1996</i>	<i>SD</i>	<i>ND</i>
95	District Sink	Moen	2008	FD	3.22
95	District Sink	Moen	2008	FD	ND
Installed Sign: Run Water for 30 Seconds Before Consumption					
98	<i>116A Hose to Tub</i>	<i>Hose</i>	<i>1996</i>	<i>FD</i>	<i>22.2</i>
98	<i>116A Hose to Tub</i>	<i>Hose</i>	<i>1996</i>	<i>SD</i>	<i>1.97</i>
Installed Sign: Not for Consumption					
99	<i>Trainers Room Ice Machine</i>	<i>Scottsman</i>	<i>2012</i>	<i>FD</i>	<i>ND</i>
99	<i>Trainers Room Ice Machine</i>	<i>Scottsman</i>	<i>2012</i>	<i>SD</i>	<i>ND</i>
100	<i>Choir Room</i>	<i>Elkay W.F.</i>	<i>1996</i>	<i>FD</i>	<i>ND</i>
100	<i>Choir Room</i>	<i>Elkay W.F.</i>	<i>1996</i>	<i>SD</i>	<i>ND</i>
101	<i>LASEC Kitchen Sink Filtered Sink</i>			<i>FD</i>	<i>ND</i>
101	<i>LASEC Kitchen Sink Filtered</i>			<i>SD</i>	<i>ND</i>
102	LASEC Kitchen Main	Faucet		FD	ND
102	LASEC Kitchen Main.	Faucet		SD	1.41
103	<i>LASEC W.F.</i>	<i>Elkay</i>	<i>2007</i>	<i>FD</i>	<i>108</i>
103	<i>LASEC W.F.</i>	<i>Elkay</i>	<i>2007</i>	<i>SD</i>	<i>111</i>
Removed Water Fountain					
104	Lobby Door 22 W.F.	Elkay	2017	FD	ND
104	Lobby Door 22 W.F.	Elkay	2017	SD	ND
105	Lobby Door 22 Bottle Filler	Elkay	2017	FD	ND
105	Lobby Door 22 Bottle Filler	Elkay	2017	FD	ND
105	Lobby Door 22 Bottle Filler	Elkay	2017	SD	ND

LIST OF WATER FOUNTAINS AND SINKS FOR DRINKING/COOKING IN 2018

#	LOCATION	TYPE	INSTALLED	DRAW	RESULT
1	Kitchen by Stove	Moen	1958	FD	2.02
1	Kitchen by Stove	Moen	1958	SD	2.08
Not for Consumption Sign Installed					
1	Kitchen by Northeast 1	Chicago	1958	FD	11.6
1	Kitchen by Northeast 1	Chicago	1958	FD	2.67
Not For Consumption Sign Installed					
1	Kitchen by East Wall 2	Chicago	1958	FD	17.3
1	Kitchen by East Wall 2	Chicago	1958	SD	1.17
Not for Consumption Sign Installed					
1	Kitchen by East Wall 3	Chicago	1958	FD	136
1	Kitchen by East Wall 3	Chicago	1958	SD	2.58
Not for Consumption Sign Installed					
1	Kitchen by East Wall 4	Chicago	1958	FD	3.13
1	Kitchen by East Wall 4	Chicago	1958	SD	1.75
Installed Sign: Run Water for 30 Seconds Before Consumption					
2	Cafeteria W.F. North (S)	Elkay EZ H2O	2016	FD	ND
2	Cafeteria W.F. North (B)	Elkay EZ H2O	2016	FD	ND
2	Cafeteria W.F. North (S)	Elkay EZ H2O	2016	SD	ND
2	Cafeteria W.F. South (S)	Elkay EZ H2O	2016	FD	ND
2	Cafeteria W.F. South (B)	Elkay EZ H2O	2016	FD	ND
2	Cafeteria W.F. South (S)	Elkay EZ H2O	2016	SD	ND
3	Academy (S)	Elkay EZ H2O	2016	FD	ND
3	Academy (B)	Elkay EZ H2O	2016	FD	ND
3	Academy (S)	Elkay EZ H2O	2016	SD	ND
4	CCC	Sink	2015	FD	6.64
4	CCC	Sink	2015	SD	ND
Not for Consumption Sign Installed					
5	HW by Rm. 100 (S)	Elkay EZ H2O	2016	FD	ND
5	HW by Rm. 100 (B)	Elkay EZ H2O	2016	SD	ND
5	HW by Rm. 100 (S)	Elkay EZ H2O	2016	FD	ND
6	HW by Rm. 104B	Halsey Taylor	2005	FD	1.01
6	HW by Rm. 104B	Halsey Taylor	2005	SD	1.60

CENTRAL CAMPUS

#	LOCATION	TYPE	INSTALLED	DRAW	RESULT
7	HW by Rm. 107 (S)	Elkay EZ H2O	2016	FD	ND
7	HW by Rm. 107 (B)	Elkay EZ H2O	2016	FD	ND
7	HW by Rm. 107 (S)	Elkay EZ H2O	2016	SD	ND
8	HW by Rm. 116 (S)	Elkay EZ H2O	2016	FD	ND
8	HW by Rm. 116 (B)	Elkay EZ H2O	2016	FD	ND
8	HW by Rm. 116 (S)	Elkay EZ H2O	2016	SD	ND
9	Pump Room	Water past Meter	1951	FD	73.2
9	Pump Room	Water past Meter		SD	43
Not for Consumption Sign Installed					
10	Rm. 206 (S)	Elkay EZ H2O	2016	FD	ND
10	Rm. 206 (B)	Elkay EZ H2O		FD	ND
10	Rm. 206 (S)	Elkay EZ H2O		SD	ND
11	Foods Lab (1)	Sink Simplice Pull Down	2017	FD	4.05
11	Foods Lab (1)	Sink Simplice Pull Down		SD	1.64
Installed Sign: Run Water for 30 Seconds Before Consumption					
11	Foods Lab (2)	Sink Simplice Pull Down	2017	FD	1.60
11	Foods Lab (2)	Sink Simplice Pull Down		SD	ND
Installed Sign: Run Water for 30 Seconds Before Consumption					
11	Foods Lab (3)	Sink Simplice Pull Down	2017	FD	1.75
11	Foods Lab (3)	Sink		SD	ND
Installed Sign: Run Water for 30 Seconds Before Consumption					
11	Foods Lab (4)	Sink Simplice Pull Down	2017	FD	3.24
11	Foods Lab (4)	Sink		SD	ND
Installed Sign: Run Water for 30 Seconds Before Consumption					
11	Foods Lab (5)	Sink Simplice Pull Down	2017	FD	2.28
11	Foods Lab (5)	Sink		SD	ND
Installed Sign: Run Water for 30 Seconds Before Consumption					
11	Foods Lab (6)	Sink Simplice Pull Down	2017	FD	1.63
11	Foods Lab (6)	Sink		SD	ND
11	Foods Lab (7)	Sink Simplice Pull Down	2017	FD	2.19
11	Foods Lab (7)	Sink		SD	ND
Installed Sign: Run Water for 30 Seconds Before Consumption					

CENTRAL CAMPUS

#	LOCATION	TYPE	INSTALLED	DRAW	RESULT
12	Rm. 224	Elkay EZ H2O	2016	FD	ND
12	Rm. 224	Elkay EZ H2O		FD	ND
12	Rm. 224	Elkay EZ H2O		SD	ND
13	Gym Girls Locker Room	Elkay EZ H2O	2016	FD	ND
13	Gym Girls Locker Room	Elkay EZ H2O		FD	ND
13	Gym Girls Locker Room	Elkay EZ H2O		SD	ND
14	Gym Boys Locker Room	Elkay EZ H2O	2016	FD	ND
14	Gym Boys Locker Room	Elkay EZ H2O		FD	ND
14	Gym Boys Locker Room	Elkay EZ H2O		SD	ND
15	South Locker Room	Halsey Taylor	2001	FD	1.87
15	South Locker Room	Halsey Taylor		SD	2.26
Removed Water Fountain from Service					
16	Room 300A	Halsey Taylor	2005	FD	1.34
16	Room 300A	Halsey Taylor		SD	1.52
17	Rm. 304	Elkay EZ H2O	2016	FD	ND
17	Rm. 304	Elkay EZ H2O		FD	ND
17	Rm. 304	Elkay EZ H2O		SD	ND
18	Rm. 332	Elkay EZ H2O	2016	FD	ND
18	Rm. 332	Elkay EZ H2O		FD	ND
18	Rm. 332	Elkay EZ H2O		SD	ND
19	Rm. 223 Aud. Stage	American Plum/ w filter	1958	FD	27.8
19	Rm. 223 Aud. Stage	American Plum/ w filter		SD	37.5
Removed Water Fountain from Service					

DISTRICT WATER SOURCES

October 20, 2018

LIST OF WATER FOUNTAINS AND SINKS FOR DRINKING/COOKING IN 2018

#	LOCATION	TYPE	INSTALLED	DRAW	RESULT
1	Tennis Courts East	Pedestal	1999	FD	19
1	Tennis Courts East	Pedestal	1999	SD	13.2
Removed from Service					
2	Soccer (S)	Elkay EZ H20	2014	FD	ND
2	Soccer (B)	Elkay EZ H20	2014	FD	ND
2	Soccer (S)	Elkay EZ H20	2014	SD	ND
3	Stadium Home Sideline	A-Frame	2015	FD	1.04
3	Stadium Home Sideline	A-Frame	2015	FD	1.04
4	Stadium Visitors Sideline	A-Frame	2014	FD	1.81
4	Stadium Visitors Sideline	A-Frame	2014	SD	ND
5	Football Sophomore Practice Field		2018	FD	2.89
5	Football Sophomore Practice Field		2018	SD	2.84
Removed from Service					
6	Football Freshman Practice Field		1999	FD	2.10
6	Football Freshman Practice Field		1999	SD	ND
Installed Sign Run Water for 30 Seconds Before Consumption					
7	Stadium Visitors Side (S)	Elkay Bottle Filler	2017	FD	4.05
7	Stadium Visitors Side (B)	Elkay Bottle Filler	2017	FD	3.26
7	Stadium Visitors Side (S)	Elkay Bottle Filler	2017	SD	3.32
7	Stadium Visitors Side (S)	Elkay Bottle Filler	2017	FD	3.72
7	Stadium Visitors Side (B)	Elkay Bottle Filler	2017	FD	5.30
7	Stadium Visitors Side (S)	Elkay Bottle Filler	2017	SD	7.11
Removed from Service					
8	Concession Home Side L	Sink	1985	FD	20.4
8	Concession Home Side L	Sink	1985	SD	1.57
8	Concession Home Side R	Sink	1985	FD	17.5
8	Concession Home Side R	Sink	1985	SD	2.08
Installed Sign Not for Consumption					
9	Concession Visitors Side L	Sink	1985	FD	4.21
9	Concession Visitors Side L	Sink	1985	SD	ND
9	Concession Visitors Side R	Sink	1985	FD	1.65
9	Concession Visitors Side R	Sink	1985	SD	ND
Installed Sign Not for Consumption					

LIST OF WATER FOUNTAINS AND SINKS FOR DRINKING/COOKING IN 2018

#	LOCATION	TYPE	INSTALLED	DRAW	RESULT
10	Concession Baseball	Sink	2015	FD	2.46
10	Concession Baseball	Sink	2015	SD	ND
Installed Sign: Run Water for 30 Seconds Before Consumption					
11	Concession Softball	Sink	2010	FD	2.26
11	Concession Softball	Sink	2010	SD	ND
Installed Sign Run Water for 30 Seconds Before Consumption					
12	Bus Barn W.F.	Elkay	2007	FD	2.99
12	Bus Barn W.F.	Elkay	2007	SD	4.62
Removed from Service Will Replace with Filtered Water Fountain					
13	Bus Barn Kitchen	Sink	2007	FD	14.8
13	Bus Barn Kitchen	Sink	2007	SD	3.31
Not for Consumption Sign Installed					
14	Grounds Shop	Sink	1996	FD	ND
14	Grounds Shop	Sink	1996	SD	ND