

**LOCATIONS OF ASBESTOS IN DISTRICT 205 SCHOOLS  
NOTIFICATION TO OUTSIDE CONTRACTORS**

**East Campus**

- Boiler Room – All the ACBM was removed from the boiler room during renovations in 1997. This includes tanks, the material on the boiler breeching and pipe fittings.
- Pipe Fittings – All ACBM has been removed from the janitor's closets, pipe chases and tunnels.
- Thermal Insulation – All ACBM has been removed from pipe chases, janitor's closets and tunnel system.
- Floor Tile and Mastic – Approximately 90,000 square feet of floor tile located in the old section of the building. The tiles are in good condition with zero friability.
- Duct Flexible Connectors – Assumed to be ACBM, located in mechanical rooms.
- Maroon Room – Approximately 900 square feet of floor tile and mastic was removed in December 1999. The room is now asbestos free.

**Central Campus**

- Ceiling Tile – Approximately 225 Square feet remain located throughout the building.
- Floor Tile and Mastic – Approximately 140,000 square feet remain in the building. The floor tile is deemed to be in good condition.
- Transite Board – Approximately 60 square feet in located in the fume hoods in the science labs. The transite board is in good condition.
- Ductwork Flexible Connectors – They are located on various fan units and are assumed to be ACBM.
- Plaster Ceiling – Approximately 18,000 square feet is located in the building.
- Plaster Walls – Approximately 75,000 square feet of ACBM is located in the building
- Pipe Insulation – Approximately 3,200 lineal fee of ACBM is located in the building.
- Boiler Room – the boiler insulation, various pipe insulation, fitting and pipe wrap is located throughout the boiler room.

**District Administrative Building**

- Plaster Ceilings – Approximately 600 square feet of plaster ceiling is assumed to be ACBM.
- Floor Tile – Approximately 400 square feet of floor tile is ACBM, which is located in the kitchen and copy room.

**Transportation Building**

- Floor Tile – Approximately 900 square feet of floor tile is ACBM.
- Ceiling Tile – Approximately 900 square feet of ceiling tile contains ACBM. The tile is located in the office area.
- Wall Board – Is assumed to be ACBM.